

**WATER QUALITY AND TREATMENT DIVISION**  
**TABLE 4 - COMPLIANCE MONITORING FY2024 (Jul 2023 - Jun 2024)**  
**SECONDARY REGULATED COMPOUNDS (mg/L - except as noted)**

**MILLER TREATED WATER**

	DETECTION LIMIT <sup>f</sup>	AVERAGE LEVEL	MAXIMUM LEVEL	MINIMUM LEVEL	SMCL <sup>a</sup>
<b>REQUIRED ANALYSES</b>					
Fluoride	0.10	0.83	0.96	0.73	2.0
<b>OPTIONAL ANALYSES</b>					
Aluminum	0.2	*	*	*	0.05-0.2
Chloride	5	24	32	13	250
Corrosivity Index <sup>c</sup>	(d)	1	2	0	≥ 0
Foaming Agents <sup>b</sup>	0.0002	*	*	*	0.5
Iron	0.04	*	*	*	0.3
Manganese	0.01	0.01	0.015	*	0.05
Odor (Threshold Odor Number) <sup>e</sup>	0	1	1	1	3
pH (Units)	(d)	8.8	9.0	8.5	7.0-10.5
Silver	0.005	*	*	*	0.1
Sulfate	5	57	72	38	250
Total dissolved solids	1	212	266	156	500
Zinc	0.01	*	*	*	5

**BOLTON TREATED WATER**

	DETECTION LIMIT <sup>f</sup>	AVERAGE LEVEL	MAXIMUM LEVEL	MINIMUM LEVEL	SMCL <sup>a</sup>
<b>REQUIRED ANALYSES</b>					
Fluoride	0.10	0.85	0.93	0.68	2.0
<b>OPTIONAL ANALYSES</b>					
Aluminum	0.2	*	*	*	0.05-0.2
Chloride	5	58	58	57	250
Corrosivity Index <sup>c</sup>	(d)	2	5	-1	≥ 0
Foaming Agents	0.0002	(d)	(d)	(d)	0.5
Iron	0.04	*	*	*	0.3
Manganese	0.01	*	*	*	0.05
Odor (Threshold Odor Number) <sup>e</sup>	0	(d)	(d)	(d)	3
pH (Units)	(d)	9.2	9.5	8.9	7.0-10.5
Silver	0.005	*	*	*	0.1
Sulfate	5	44	45	42	250
Total dissolved solids	1	249	286	224	500
Zinc	0.01	*	*	*	5

\* Below detection limit.

- (a) SMCL is the secondary maximum contaminant level of the material as specified in the "Safe Drinking Water Act," Public Law 93-523 or "Ohio EPA secondary contaminant standards" Ohio Administrative Code 3745-82, whichever is more stringent.
- (b) Analyses not performed in FY2024. Most recent data shown.
- (c) Marble Alkalinity
- (d) Not applicable.
- (e) Dechlorinated odor.
- (f) The detection limit indicates the lowest concentration of a substance that can be reliably measured by the analytical procedure and may be a method detection limit, reporting limit, or practical quantitation limit.